

THE UNIVERSITY OF CONNECTICUT

PROPOSAL CLARIFICATION #1

September 16, 2009

DUE DATE: September 17, 2009
TIME: 2:00 p.m.
PROJECT: Emergency Repair-Steam and Condensate Line
PROJECT NO: BI-901498
LOCATION: University of Connecticut
Capital Projects & Contract Administration
31 LeDoyt Road
Storrs, CT
Attn: Mary Kate Sullivan

Please note the following clarifications:

1. The University of Connecticut's RFI Log dated September 16, 2009. Attached.

Qualifications of Firm

- A. Request for Proposal (RFP) will be considered only from those firms or persons with a demonstrated and substantial history of experience in successfully providing analyses and studies in the areas identified in this request whose requirements are similar in size and scope to those of the University. Preference will be given to firms with such confirmed experience.
- B. Prospective firms must be prepared to provide any evidence of experience, performance ability and/or financial surety the University deems necessary to fully establish the performance capabilities represented in their RFP.
- C. The University will reject the RFP of any firm and void any award resulting from this Request to any firm who makes any material misrepresentation in their RFP.

University of Connecticut

Mary Kate Sullivan, Purchasing Agent II
Capital Project & Contract Administration

Emergency Repair-Steam and Condensate Line

9/16/2009 10:08

Project BI 901498

<u>RFI No.</u>	<u>Question</u>	<u>Response</u>
1	How many buildings will have to be provided with temporary boilers for the period of construction?	There are nineteen buildings that may potentially require temporary boilers during construction. However, pending other construction projects and the construction schedule for this project many of these buildings may not require temporary boilers.
2	Do you have soil tests or geotechnical reports available indicating the corrosive nature of the soil in the project area?	There is no geotechnical data available at this time, limited geotechnical information may be available to the selected design team.